

BM TRADA

Results of Test: BMT/MTP/F14266/01/A/Rev2

Portrisa S.A

Ponte da Pedra
2415 - 926
Leiria
Portugal

This document confirms that performance testing was conducted on 13 October 2014 to 14 October 2014. Testing was conducted to the following standards:

- BS 6375 Part 1: 2009 Performance of windows and doors – Part 1: Classification for weathertightness and guidance on selection and specification
- PAS 24: 2012 Enhanced security performance requirements for doorsets and windows in the UK

The following results were achieved:

Product tested	START/MAX Single leaf doorset (inward opening)		
Summary of testing procedure			Result
	Test Standard	Classification Standard	
Air permeability	BS EN 1026: 2000	BS EN 12207: 2000	300Pa (Class 2)
Watertightness	BS EN 1027: 2000	BS EN 12208: 2000	200Pa (Class 5A)
Wind resistance	BS EN 12211: 2000	BS EN 12210: 2000	1200Pa (Class A3)
Exposure category		BS 6375: Part 1: 2009	1200
PAS 24: 2012 – Clauses A.3, B.4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.7, B.4.8 and B.4.9			Pass

Air leakage at 50pa was 1.7m³/h positive pressure and 2.1m³/h negative pressure. The perimeter length of opening light was 6.2m.

Passed PAS 24: 2012 for the requirements of both key removable and thumbturn locks

The results relate only to the specimens tested, as detailed in the technical specification

Revision 1 – Amendment to leaf facing details on page 4.

Revision 2 – Amendment to sponsor name, lipping details and drawings on pages 1, 2, 3 and Appendix 1



Issued by:
James Bacchus - Technical Officer



Authorised by:
Lee Grant-Riach - Technical Officer
Issue date: 15th June 2015

BM TRADA

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, UK

Tel: 01494 569800 Fax: 01494 564895

Web: www.bmtradagroup.com Email: testing@bmtrada.com

This document is confidential and remains the property of Chiltern International Fire Ltd, trading as BM TRADA



1762